

1 RESULTS TABLE:

Sample #	Location	1 st draw (FD)	Results (ppb)	LCR Action Level ⁽¹⁾ (ppb)
1	Classroom 107	FD	1.26	15
2	Classroom 106	FD	ND	15
3	Nurse 104	FD	2.53	15
4	Nurse 104	FD	1.52	15
5	Classroom 105	FD	2.35	15
6	Faculty Room 109	FD	2.12	15
7	Multipurpose Room 110	FD	2.43	15
8	Classroom 111	FD	1.39	15
9	Classroom 121	FD	1.78	15
10	Classroom 112	FD	2.91	15
11	Classroom 113	FD	ND	15
12	Classroom 114	FD	1.19	15
13	Classroom 119	FD	4.39	15
14	Classroom 115	FD	ND	15
15	Classroom 118	FD	ND	15
16	Classroom 116	FD	ND	15
17	Hallway at Gym 117	FD	ND	15
18	Hallway at Gym 117	FD	ND	15
19	Classroom 124	FD	88.4	15
20	Hallway at 122/131	FD	ND	15
21	Hallway at 122/131	FD	ND	15
22	Media Center 130	FD	1.40	15
23	Classroom 125	FD	782	15
24	Classroom 126	FD	2.64	15
25	Classroom 127	FD	428	15
26	Classroom 128	FD	170	15
27	Classroom 129	FD	153	15
28	Classroom 203	FD	2.23	15
29	Classroom 202	FD	ND	15
30	Classroom 204	FD	2.70	15
31	Classroom 210	FD	1.43	15
32	Classroom 208	FD	1.47	15
33	Classroom 205	FD	1.91	15
34	Classroom 207	FD	2.19	15
35	Classroom 211	FD	1.14	15
36	Classroom 201	FD	2.64	15
37	Classroom 206	FD	3.15	15
38	Blank	FD	ND	15

1 RESULTS TABLE:

Sample #	Location	1 st draw (FD)	Results (ppb)	LCR Action Level ⁽¹⁾ (ppb)
1	BR.DW.FI-1.107	FD	1.26	15
2	BR.DW.FI-1.106	FD	ND	15
3	BR.NS.FI-1.Nurse	FD	2.53	15
4	BR.TS.FI-1.Nurse	FD	1.52	15
5	BR.DW.FI-1.105	FD	2.35	15
6	BR.TL.FI-1.109	FD	2.12	15
7	BR.WC.FI-1.110	FD	2.43	15
8	BR.DW.FI-1.111	FD	1.39	15
9	BR.DW.FI-1.121	FD	1.78	15
10	BR.DW.FI-1.112	FD	2.91	15
11	BR.DW.FI-1.113	FD	ND	15
12	BR.DW.FI-1.114	FD	1.19	15
13	BR.DW.FI-1.119	FD	4.39	15
14	BR.DW.FI-1.115	FD	ND	15
15	BR.DW.FI-1.118	FD	ND	15
16	BR.DW.FI-1.116	FD	ND	15
17	BR.WC.FI-1.117A	FD	ND	15
18	BR.WC.FI-1.117B	FD	ND	15
19	BR.DW.FI-1.124	FD	88.4	15
20	BR.WC.FI-1.131-1	FD	ND	15
21	BR.WC.FI-1.131-2	FD	ND	15
22	BR.MS.FI-1.130	FD	1.40	15
23	BR.DW.FI-1.125	FD	782	15
24	BR.DW.FI-1.126	FD	2.64	15
25	BR.DW.FI-1.127	FD	428	15
26	BR.DW.FI-1.128	FD	170	15
27	BR.DW.FI-1.129	FD	153	15
28	BR.DW.FI-2.203	FD	2.23	15
29	BR.DW.FI-2.202	FD	ND	15
30	BR.DW.FI-2.204	FD	2.70	15
31	BR.DW.FI-2.210	FD	1.43	15
32	BR.DW.FI-2.208	FD	1.47	15
33	BR.DW.FI-2.205	FD	1.91	15
34	BR.DW.FI-2.207	FD	2.19	15
35	BR.DW.FI-2.211	FD	1.14	15
36	BR.DW.FI-2.201	FD	2.64	15
37	BR.DW.FI-2.206	FD	3.15	15
38	Blank	FD	ND	15