

**1 RESULTS TABLE:**

Sample #	Location	1 <sup>st</sup> draw (FD)	Results (ppb)	LCR Action Level <sup>(1)</sup> (ppb)
1	Kichen off of MPR 119	FD	5.35	15
2	Copy Room 127	FD	79.8	15
3	Principal's Office	FD	19.6	15
4	Hallway at 128	FD	ND	15
5	Hallway at 128	FD	ND	15
6	Classroom 101	FD	1.15	15
7	Nurse 117	FD	1.31	15
8	Nurse 117	FD	1.58	15
9	Classroom 102	FD	4.51	15
10	Classroom 103	FD	ND	15
11	Faculty Room 116	FD	1.32	15
12	Classroom 112	FD	ND	15
13	Classroom 111	FD	ND	15
14	Classroom 104	FD	6.81	15
15	Classroom 105	FD	1.72	15
16	Classroom 106	FD	ND	15
17	Classroom 108	FD	1.15	15
18	Classroom 109	FD	1.70	15
19	Classroom 110	FD	ND	15
20	Hallway at Gym 122	FD	ND	15
21	Hallway at Gym 122	FD	ND	15
22	Classroom 107	FD	1.44	15
23	Classroom 130	FD	1.12	15
24	Classroom 131	FD	ND	15
25	Hallway at 200	FD	ND	15
26	Hallway at 200	FD	ND	15
27	Classroom 201	FD	ND	15
28	Classroom 202	FD	1.30	15
29	Classroom 203	FD	1.10	15
30	Media Center 216	FD	1.90	15
31	Classroom 213	FD	ND	15
32	Classroom 212	FD	ND	15
33	Classroom 211	FD	ND	15
34	Classroom 204	FD	ND	15
35	Classroom 205	FD	ND	15
36	Classroom 206	FD	1.55	15
37	Classroom 207	FD	1.27	15
38	Classroom 208	FD	1.66	15
39	Classroom 209	FD	1.04	15
40	Classroom 210	FD	1.31	15

**1 RESULTS TABLE:**

Sample #	Location	1 <sup>st</sup> draw (FD)	Results (ppb)	LCR Action Level <sup>(1)</sup> (ppb)
1	SO.FP.FI-1.119	FD	5.35	15
2	SO.CS.FI-1.127	FD	79.8	15
3	SO.TS.FI-1.128	FD	19.6	15
4	SO.WC.FI-1.128-1	FD	ND	15
5	SO.WC.FI-1.128-2	FD	ND	15
6	SO.DW.FI-1.101	FD	1.15	15
7	SO.NS.FI-1.Nurse	FD	1.31	15
8	SO.TS.FI-1.Nurse	FD	1.58	15
9	SO.DW.FI-1.102	FD	4.51	15
10	SO.DW.FI-1.103	FD	ND	15
11	SO.TL.FI-1.116	FD	1.32	15
12	SO.DW.FI-1.112	FD	ND	15
13	SO.DW.FI-1.111	FD	ND	15
14	SO.DW.FI-1.104	FD	6.81	15
15	SO.DW.FI-1.105	FD	1.72	15
16	SO.DW.FI-1.106	FD	ND	15
17	SO.DW.FI-1.108	FD	1.15	15
18	SO.DW.FI-1.109	FD	1.70	15
19	SO.DW.FI-1.110	FD	ND	15
20	SO.WC.FI-1.Gym-1	FD	ND	15
21	SO.WC.FI-1.Gym-2	FD	ND	15
22	SO.DW.FI-1.107	FD	1.44	15
23	SO.DW.FI-1.130	FD	1.12	15
24	SO.DW.FI-1.131	FD	ND	15
25	SO.WC.FI-2.200-1	FD	ND	15
26	SO.WC.FI-2.200-2	FD	ND	15
27	SO.DW.FI-2.201	FD	ND	15
28	SO.DW.FI-2.202	FD	1.30	15
29	SO.DW.FI-2.203	FD	1.10	15
30	SO.MS.FI-2.216	FD	1.90	15
31	SO.DW.FI-2.213	FD	ND	15
32	SO.DW.FI-2.212	FD	ND	15
33	SO.DW.FI-2.211	FD	ND	15
34	SO.DW.FI-2.204	FD	ND	15
35	SO.DW.FI-2.205	FD	ND	15
36	SO.DW.FI-2.206	FD	1.55	15
37	SO.DW.FI-2.207	FD	1.27	15
38	SO.DW.FI-2.208	FD	1.66	15
39	SO.DW.FI-2.209	FD	1.04	15
40	SO.DW.FI-2.210	FD	1.31	15